



Jim Doyle, Governor
Mary P. Burke, Secretary

July 14, 2004

PERFORMANCE PIPE
CHEVRON PHILLIPS CHEMICAL COMPANY
HEATH CASTEEL
5085 W PARK BLVD SUITE 500
PLANO TX 75026-9006

Re: Description: PIPES, POLYETHYLENE
Manufacturer: PERFORMANCE PIPE
Product Name: DRISCOPEX PW 1500 AND 1600 SERIES
Model Number(s): PIPE: DRISCOPEX PW 1500 3" THROUGH 24" AND DRISCOPEX PW 1500 4" THROUGH 24"
Product File No: 20040326

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (4) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2009.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product must be labeled with the following information:
 - a. National standard to which the pipe meets
 - b. The letters PE followed by the cell classification
 - c. Nominal pipe outside diameter
 - d. Dimensional ratio or pressure rating
 - e. Manufacturer's name or trademark
 - f. Production code and date of manufacture
 - g. Seal or mark of accredited laboratory indicating the product is suitable for potable water
- This product may be installed for the following water use(s):
 - a. Water service and private water main
- Pipe must have a dimensional ratio of DR9.3, DR9 and DR7.3.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov